

# HIGH TEMPERATURE GLYCOL FEED SYSTEMS SYSTEM SPECIFICATIONS

WSS161002.C 03/18



## DESCRIPTION

1.0) **AUTOMATIC GLYCOL FEED PACKAGE:** High temperature glycol feed systems shall consist of a 12ga carbon steel tank, hinged carbon steel lid, carbon steel frame, NEMA 4X control panel, low level float switch, 1/3HP open motor bronze rotary vane pump with internal relief valve, pressure switch, relief valve, check valve, threaded carbon steel plumbing, and high temperature hoses.

## MATERIALS

2.0) **TANK AND FRAME:** Carbon steel tank shall be minimum 12ga with 1/3 hinged carbon steel lid. Tank stand frame shall be constructed of carbon steel with bracing for plumbing and control panel. Tank frame shall have 12ga pump mount shelf and be coated with epoxy paint. (Check size below.)

- 15 Gallon tank and stand
- 30 Gallon tank and stand
- 50 Gallon tank and stand
- 100 Gallon tank and stand

2.1) **PUMP:** Pump shall be close-coupled with internal pressure relief valve. Standard pump will be capable of 1.6 GPM @ 100 PSI. Pump motor is 1/3HP, 110/120 VAC, 1 phase, 60 hertz, open drip proof type and will be wired to control panel. (Options below.)

- 1/2HP with an output of 3.6 GPM @ 100 PSI
- Dual pumps, discharge manifold, and suction manifold, (not available on 15 gallon system.)

2.2) **PRESSURE SWITCH:** Pressure switch shall be designed for pressures as indicated below. Pressure switch will be prewired to the control panel to turn the pump on and off based on rising and falling pressure settings. (Check one below.)

- Code 1 (10-45 PSI cut-in, 20-60 PSI cut-out, 10-30 PSI pressure differential)
- Code 2 (40-80 PSI cut-in, 65-100 PSI cut-out, 20-40 PSI pressure differential)
- Code 3 (3-10 PSI cut-in, 9-30 PSI cut-out, 6-20 PSI pressure differential)
- Code D\* (0-149 PSI cut-in, 1-150 PSI cut-out, 1-149 PSI pressure differential)
- Code X (no pressure switch)

*\*D Represents change Digital Glycol Feed System*

2.3) **CONTROL PANEL:** Polycarbonate NEMA 4X lockable control panel shall be of ample size for equipment needs and servicing of electrical components. All exterior components shall be rated NEMA 4X and installed per manufacturer's instructions. Wiring and wiring diagram shall be color-coded for easy trouble shooting. All internal wire shall be 16ga minimum. Controls are, but not limited to, main power switch and indicator light, pump hand/off/ auto switch and indicator light and red low-level indicator light.

2.4) **PRESSURE RELIEF VALVE:** Pressure relief valve shall be Conbraco model 16-501-01, constructed of bronze with a nitrile diaphragm.

2.5) **CHECK VALVE:** Back flow check valve shall be a soft seat design. Bronze construction with stainless steel spring and raised radius valve seat for positive seal.

2.6) **LOW LEVEL SWITCH:** Polypropylene low level switch shall be interlocked with pump feed and low level indicator. Low level will stop all pump operations when level falls below the factory set point.

# HIGH TEMPERATURE GLYCOL FEED SYSTEMS SYSTEM SPECIFICATIONS

WSS161002.C 03/18



## 2.7) **OPTIONAL FEATURES:** (Check all that apply below.)

- AUDIBLE ALARM:** Audible alarm shall be 95 decibel @ 10ft with silence switch that will sound on low level, (Option B).
- LOW LEVEL DRY CONTACT:** Dry contact shall be SPST NO switch that is wired to level switch for control room signal, (Option C).
- EXPANSION TANK:** 4.5 gallon expansion tank with adjustable pressure reducing valve, Max. Pressure: 70 PSI (Option ET).
- HIGH LEVEL DRY CONTACT:** Dry contact shall be SPST NO switch that is wired to level switch for control room signal, (Option HC).
- MIXER:** TEFC stand mounted mixer with On-Off switch. 1/20HP for units less than or equal to 55 gallon, 1/4HP for units greater than 55 gallons, (Option MXR).
- TEFC:** Totally Enclosed Fan Cooled pump motor in place of the standard ODP pump, (Option TEFC).
- OUTDOOR:** Outdoor rated system with a bolted down cover and TEFC pump, (Option OUTDOOR).

3.0) **WARRANTY:** Wingert Glycol Feed Systems are warranted against manufacturing defects in material and workmanship for one year from the date of shipment. Applications outside the service for which the product is designed will automatically void any warranty. J.L. Wingert Co. will repair or replace a defective unit when returned to the factory with transportation prepaid. Final determination will be made upon inspection. J.L. Wingert Co. assumes no liability for labor and/or other expenses in making repairs or adjustments. All replacements will be F.O.B. factory. There are no other implied or expressed warranties.

The pump is not manufactured by J.L. Wingert Co. and thus is warranted by the original manufacturer. Repair or replacement is contingent upon inspection and determination by the original manufacturer. Their findings are final and beyond our control.