



| PARTS LIST | | |
|------------|-----------------|---|
| KEY | ITEM | DESCRIPTION |
| 1 | INLET | 5" FF 150# |
| 2 | STRAINER | 5" CAST IRON STRAINER W/ STAINLESS STEEL BASKET |
| 3 | PUMP | GOULDS: 10AI2N9H0 600 GPM @ 80TDH 20HP TEFC MOTOR |
| 4 | SKID | EPOXY COATED CARBON STEEL |
| 5 | CONTROL PANEL | NEMA 4X ENCLOSURE MAIN POWER DISCONNECT MAIN POWER LED INDICATOR PUMP H-O-A SWITCH PUMP RUNNING LED INDICATOR PURGE H-O-A SWITCH SYSTEM PURGING LED INDICATOR ALARM LED INDICATOR 460VAC TO 120VAC TRANSFORMER PUMP CONTACTOR AND OVERLOAD PROGRAMMABLE PURGE CONTROLLER REMOTE START/STOP TERMINALS (24VDC) REMOTE PURGE TERMINALS (24VDC) |
| 6 | SEPARATOR | XFD-0500 FLOW RATE AT 4 PSID: 554 GPM FLOW RATE AT 12 PSID: 959 GPM |
| 7 | MOTORIZED PURGE | 1-1/2" FNPT 120VAC FULL PORT MOTORIZED BALL VALVE |
| 8 | DISCHARGE | 5" RF 150# |



| | | | | |
|----------|----|-----------|---|--------------|
| DRAWN | RB | 4/23/2020 | J.L. WINGERT CO. | |
| CHECKED | | | | |
| QA | | | TITLE | |
| MFG | | | JLW 600GPM @ 80TDH SEPARATOR SYSTEM - SUBMITTAL | |
| APPROVED | | | SIZE | REV |
| | | | C | DWG NO |
| | | | CT-0600-80-MPK_BS | |
| | | | SCALE | SHEET 1 OF 1 |
| | | | 0.09 : 1 | |

| | |
|--|--|
| | |
|--|--|

| | | |
|--|--|--|
| | | |
|--|--|--|

