



| PARTS LIST | | |
|------------|---------------|---|
| KEY | PART NUMBER | DESCRIPTION |
| 1 | INLET | 6" 125# FF FLANGE |
| 2 | STRAINER | 6" CAST IRON STRAINER WITH STAINLESS STEEL BASKET |
| 3 | PUMP | GOULDS 15AI2N9K0 850 GPM @ 80 TDH 20HP TEPE |
| 4 | SKID | EPOXY COATED CARBON STEEL |
| 5 | CONTROL PANEL | NEMA 4X ENCLOSURE MAIN POWER DISCONNECT MAIN POWER LED INDICATOR PUMP H-O-A SWITCH PUMP RUNNING LED INDICATOR PURGE H-O-A SWITCH SYSTEM PURGING LED INDICATOR ALARM LED INDICATOR 460VAC TO 120VAC TRANSFORMER PUMP CONTACTOR AND OVERLOAD PROGRAMMABLE PURGE CONTROLLER REMOTE START/STOP TERMINALS (24VDC) REMOTE PURGE TERMINALS (24VDC) |
| 6 | SEPARATOR | XFD-0500 554-959 GPM |
| 7 | PURGE | 1-1/2" FPT MOTORIZED 120VAC PURGE VALVE |
| 8 | DISCHARGE | 5" 150# RF FLANGE |

| | | | |
|----------|----|-----------|--------------------------------------|
| DRAWN | RB | 10/7/2020 | J.L. WINGERT CO. |
| CHECKED | | | |
| QA | | | TITLE |
| MFG | | | JLW 850 GPM @ 80TDH SEPARATOR SYSTEM |
| APPROVED | | | SIZE |
| | | | DWG NO |
| | | | CT-0850-80-MPK/BS - Submittal |
| | | | REV |
| | | | SCALE 0.09 : 1 |
| | | | SHEET 1 OF 1 |

| | |
|--|--|
| | |
|--|--|

| | | |
|--|--|--|
| | | |
|--|--|--|

