



PARTS LIST		
KEY	ITEM	DESCRIPTION
1	INLET	6IN 125# FF FLANGE
2	STRAINER	6IN CAST IRON BASKET STRAINER WITH STAINLESS STEEL BASKET
3	PUMP	GOULDS: 15A12P9G0 1200 GPM @ 40'TDH 25HP TEPE
4	SKID	EPOXY COATED CARBON STEEL
5	CONTROL PANEL	NEMA 4X ENCLOSURE MAIN POWER DISCONNECT MAIN POWER LED INDICATOR PUMP H-O-A SWITCH PUMP RUNNING LED INDICATOR PURGE H-O-A SWITCH SYSTEM PURGING LED INDICATOR ALARM LED INDICATOR 460VAC TO 120VAC TRANSFORMER PUMP CONTACTOR AND OVERLOAD PROGRAMMABLE PURGE CONTROLLER REMOTE START/STOP TERMINALS (24VDC) REMOTE PURGE TERMINALS (24VDC) WIRED FOR 460VAC/3Ph/60Hz
6	SEPARATOR	XFD-0600 FLOW AT 4 PSID: 800 GPM FLOW AT 12 PSID: 1,385 GPM
7	PURGE	1-1/2" FPT MOTORIZE PURGE VALVE
8	DISCHARGE	6IN 150# RF FLANGE

DRAWN	1/29/2021
RB	
CHECKED	
MATERIAL	
FINISH	
EPOXY PAINT	
MACHINED TOLERANCE:	
± 0.005 INCHES	
FABRICATED TOLERANCE:	
± 0.063 INCHES	



TITLE		JLW 1200 GPM @ 40' TDH SEPARATOR SYSTEM	
SIZE	DWG NO	REV	
SCALE	CT-1200-40-MPK/BS - Submittal		
.1:1			SHEET 1 OF 1

--	--

--	--	--

