## DOUBLE WALL TANK SPECIFICATIONS

WSS130400.B 01/17



## **DESCRIPTION**

1.0) **DOUBLE WALL TANK:** Shall consist of an outer (secondary) polyethylene tank and an inner (primary) polyethylene tank.

## **MATERIALS**

| 2.0) | <b>TANK:</b> The tanks shall be constructed via rotational molding. The tanks shall be constructed from material that has long term UV8 stabilization and NSF and UL recognition. All –LL models are to be supplied in linear low density polyethylene. Standard tank color is natural. (Check size.) |
|------|---|
|      | □ 1830-LL (18 Gallon Primary Tank, 30 Gallon Secondary Tank)  |
|      | ☐ 3550-LL (35 Gallon Primary Tank, 50 Gallon Secondary Tank)  |
|      | ☐ 6590-LL (65 Gallon Primary Tank, 90 Gallon Secondary Tank)  |
|      | ☐ 120160-LL (120 Gallon Primary Tank, 160 Gallon Secondary Tank)  |
|      | ☐ 160210-LL (160 Gallon Primary Tank, 210 Gallon Secondary Tank)  |
|      | ☐ 220330-LL (220 Gallon Primary Tank, 330 Gallon Secondary Tank)  |
| 2.1) | MANWAY: Double wall tanks shall include a vented manway with a minimum diameter of 8 inches.  |
| 2.2) | <b>AUXILARY PORT(S):</b> All double wall tanks shall include one (1) 2" FNPT spun weld fitting with plug on the top of the primary tank.  |
| 2.3) | <b>PUMP MOUNT(S):</b> All tanks shall include at least one (1) recess for mounting a chemical metering pump. The recess shall include a hole with a removable plug for the chemical metering pump's suction assembly.   |
| 2.4) | OPTIONAL FEATURES: (Check all that apply.)  |
|      | ☐ BLUE: Color of the tank to be blue in lieu of the standard natural color.   |
|      | ☐ BLACK: Color of the tank to be black in lieu of the standard natural color.   |
|      | ☐ LEVEL INDICATOR: Direct reading level gauge. Gauge to represent volume as Full, 7/8, 3/4, 5/8, 1/2, 3/8, 1/4, 1/8 and Empty.  |
|      |   |

3.0) **WARRANTY:** J.L. Wingert double wall tanks are guaranteed for one year from the date of shipment against manufacturing defects in material and/or workmanship. J.L. Wingert Company will repair or replace defective